

COOPERATIVE LOSS AND SAFETY PROGRAM (CLASP)

Heating equipment

- Is heating system serviced by an outside contractor? Yes No N/A
- If heating system includes a closed pressure vessel, is inspection permit visible and current? Yes No N/A
- Is furnace room clean and free of storage materials and combustibles? Yes No N/A
- Are heating and exhaust systems, particularly where they're vented through walls or roofs, in good shape? Yes No N/A

Lighting and electrical equipment

- Is installation, service, and repair work done by a licensed electrician? Yes No N/A
- Is all the wiring permanent (no temporary wiring used)? Yes No N/A
- Are ground fault outlets used near all sources of water (kitchen, bathrooms, janitor closet, etc.?) Yes No N/A
- Are all electrical outlets and boxes covered and properly maintained? Yes No N/A
- Are all exit lights visible and working? Yes No N/A

Protection

- Are fire extinguishers visible and accessible (within 75 feet)? Yes No N/A
- Are fire extinguishers, automatic sprinklers, hoses, and detection systems charged, tagged and inspected? Yes No N/A
- Are all exits unobstructed and unlocked during building use? Yes No N/A

General condition

- Have kitchen range ventilation hoods, filters, suppression systems, and ducts been professionally cleaned and serviced? Yes No N/A
- Is kitchen equipment (stoves, grills, etc.) in good working order and properly maintained? Yes No N/A
- Is there adequate exterior lighting including sidewalks and parking lots? Yes No N/A
- Are doors and windows adequately secured? Yes No N/A
- Is general condition of building structure (exterior walls, windows, roofing, gutters) in good repair? Yes No N/A
- Are sidewalks and parking lots in good repair? Yes No N/A
- Does church leadership demonstrate a responsible attitude toward maintaining the facility? Yes No N/A
- Are all floor surfaces in good condition, free from tripping/slipping hazards? Yes No N/A
- Are all stairways in good condition and well lit? Yes No N/A
- Are there solid handrails for all steps and stairways? Yes No N/A
- Is there a formal snow and ice removal plan for lots and walkways? Yes No N/A
- Are all buildings equipped with emergency lighting that activates during power loss? Yes No N/A
- Are all exit doors equipped with panic hardware and unlocked during occupancy? Yes No N/A

Facilities: Do any of the buildings have the following items?:

- Elevators, escalators, lifts Yes No
- Indoor gymnasium Yes No
- Fitness or exercise training Yes No
- Weight training equipment Yes No
- Balconies or lofts Yes No